

02 Fire safety procedures

02.1 Fire safety

- The setting manager has access to, or a copy of, the fire safety procedures specific to the building and ensure they align with these procedures. The setting manager makes reasonable adjustments as required to ensure the two documents do not contradict each other.

Fire safety precautions include:

- All electrical equipment is checked by a qualified electrician annually.
- Any faulty electrical equipment is taken out of use and recorded as such or condemned (whichever is necessary).
- Sockets are covered. This is different to using plug sockets inserts, a socket cover, covers the whole socket, including the switch and is safe to use.
- Water and electrical items do not come into contact; staff do not touch electrical items with wet hands.
- All fire safety equipment is checked annually.
- Gas boilers and cookers are checked and serviced annually by a Gas Safe registered engineer.
- If matches are used in the kitchen, they are kept in a drawer.
- Oxygen tanks.

Fire Drills

- Fire Drills (to include emergency evacuation procedures and lock down) are held at least termly.
- Drills are recorded, including:
 - date of drill
 - staff involved and numbers of children
 - how long it took to evacuate
 - any reason for a delay in achieving the target time and how this will be remedied

Fire precautions

- Fire exit signs are the green 'running man' signs and are in place and clearly visible.
- Fire exits by doors are those that show a green light at night.
- Fire doors are not locked during normal working hours.
- Fire evacuation notices are in every room; these are displayed in print large enough to read from a short distance. They say where the assembly point is.

- Fire alarms are in place and tested monthly, and where necessary supplemented with visual warnings. This is recorded.
- Smoke alarms are in place and tested monthly. This is recorded.
- A fire blanket is in place in the kitchen (and any other location where there is a cooker).
- Fire extinguishers are in place and are appropriate

Further guidance

[Dynamic Risk Management](#) (Alliance Publication)

[Fire Safety Record](#) (Alliance Publication)

Fire Safety Risk Assessment: Educational Premises (HMG 2006):

www.gov.uk/government/publications/fire-safety-risk-assessment-educational-premises