

Siderise Innovation Centre Summary of Results
Test Number SIC 368



Test Standard; Principles of TGD19 (prEN1364-6)

Furnace Control: EN1363-1 & 2 utilising the external Time Temperature Curve

Tested James & Taylor Barracuda brickslip system and carrier rails fixed to SFS in horizontal & vertical brick configuration with a void size of 380mm

Material; Siderise RH25 90/30 open state cavity barrier

On 27th November 2025 a Fire Resistance test was carried out on a 1200mm length of Siderise RH25 90/30 installed into a James & Taylor Barracuda brickslip system.

Siderise RH25 90/30 was installed as per standard installation guidance, complete with three supporting brackets and 25mm air gap to back of carrier panel.

The test utilised the principles of TGD19 (prEN1364-6), due to the bespoke build up being tested in conjunction with Siderise cavity barriers, with furnace controls temperature and pressure run to EN1363-1 & 2 utilising the external time temperature curve, the test was run for a duration of 90 minutes in totality.

Please find attached relevant data output and summary of test below.

Orientation of Brick	Summary Table	Insulation (min)	Integrity (min)
Vertical	Siderise RH25 90/30	90	90
	Stock Frogged Brick	15	90
	Extruded Brick	23	90
	Supporting Rails	4	90
Horizontal	Siderise RH25 90/30	90	90
	Stock Frogged Brick	22	90
	Extruded Brick	31	90
	Supporting Rails	90	92


Air gap closure between 60 and 90 seconds closing phase of the air gap, for both samples


Note test terminated at 90 minutes (ambient lab temperature 18°C)


This summary report is whilst following the strict controls of EN1363-1 & 2 utilising the external time temperature curve and general principles of TGD19 (prEN1364-6), this is not a UKAS test report.

For and behalf of Siderise Insulation Ltd


Director of Testing & Project Engineering








Siderise Innovation Centre Summary of Results
Test Number SIC 368





Pre Test Photographs



Post Test Photographs



