



Certificate number: 2403732 (1)

Issued 22/03/2024

Expires 22/03/2029

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Purewater Storage Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Purewater Storage Ltd
40-46 Mariner
Tamworth
B79 7UL
United Kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2403732

The following products belong to this certificate

PRODUCT DESCRIPTION 'PW' range of insulated GRP one-piece and two-piece water storage tanks. ATS3 – Without Production Surveillance.
MODEL(S) PW range.
SIZE: 90 litres to 12000 litres.
SCOPE: Manufacturer recommended maximum working pressure: n/a & maximum operating temperature: Cold water use only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only.
MARKING Purewater, contact information, capacity and other technical information.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements Every storage cistern, except one supplying water to the primary circuit of a heating system, shall be fitted with a servicing valve on the outlet pipe (s). A servicing valve shall be installed on the supply to the fitting in a readily accessible location. Approval doesn't include inlet connections or float valves.

Extra Notes