



TITLE
PW1000.INS.AG

NOTE:
All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DRAWN BY C.MORRIS DATE 05/05/2023

CUSTOMER

ALL DIMENSIONS +/- 5mm
UNLESS OTHERWISE STATED

A4

ALL DIMENSIONS IN MM - DO NOT SCALE

DATE 09/10/2017 VERSION A NOTES FIRST ISSUE

TANK SPECIFICATION :		
INTERNAL DIMENSIONS	1000 x 1000 x 1000mm	
EXTERNAL DIMENSIONS	1160 x 1160 x 1093mm	
NOM. CAPACITY	1000 Litres	
DRY WEIGHT	54 KG	
INSULATION THICKNESS	25mm	
WRAS CERT. NUMBER	131006	
MATERIAL	GRP	

purewater
Storage Ltd

SCALE:1:20 SHEET 1 OF 1