



| | |
|-------------------------------|--------------------|
| TITLE PW3000.INS.AG | |
| DRAWN BY J. Ellison | DATE 18/05/2023 |
| CUSTOMER CUSTOMER | |

| |
|---|
| NOTE: All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank. |
| ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED |

| |
|---|
| DESCRIPTION: PW3000 one piece cold water storage tank suitable for AG/AF Air gap |
| A4 |
| ALL DIMENSIONS IN MM - DO NOT SCALE |

| DATE | VERSION | NOTES |
|------------|---------|-------------|
| 26/10/2017 | A | FIRST ISSUE |
| | | |
| | | |
| | | |
| | | |

| TANK SPECIFICATION : | |
|----------------------|----------------------|
| INTERNAL DIMENSIONS | 3000 x 1000 x 1000mm |
| EXTERNAL DIMENSIONS | 3202 x 1202 x 1093mm |
| NOM. CAPACITY | 3000 Litres |
| DRY WEIGHT | 195 KG |
| INSULATION THICKNESS | 25mm |
| WRAS CERT. NUMBER | 131006 |
| MATERIAL | GRP |

SCALE:1:30 SHEET 1 OF 1