


TITLE		NOTE: All Purewater tanks must be fully supported on a flat,level & continuous foundation providing structural support to the tank when full to maximum operating capacity.It is essential that the user refers to the conditions of installation document prior to the installation of the tank.Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.		DESCRIPTION: PW454 one piece cold water storage tank suitable for AG/AF Air gap		DATE 18/09/2017		VERSION A		NOTES FIRST ISSUE		TANK SPECIFICATION :			
PW454.INS.AG										INTERNAL DIMENSIONS		1067 x 610 x 710mm			
										EXTERNAL DIMENSIONS		1245 x 795 x 727mm			
										NOM. CAPACITY		454 Litres			
										DRY WEIGHT		30 KG			
										INSULATION THICKNESS		25mm			
DRAWN BY C.MORRIS		DATE 03/05/2023										WRAS CERT. NUMBER		131006	
CUSTOMER CUSTOMER		ALL DIMENSIONS+/- 5mm UNLESS OTHERWISE STATED		A4		ALL DIMENSIONS IN MM - DO NOT SCALE						MATERIAL		GRP	
														SCALE:1:15	
														SHEET 1 OF 1	