



TITLE		NOTE:	DESCRIPTION:	DATE			VERSION	NOTES	TANK SPECIFICATION :	
PW4001.INS-2 (AG)		All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.	PW4001-2 piece cold water storage tank suitable for AG/AF Air gap	15/12/2021	A	FIRST ISSUE			INTERNAL DIMENSIONS	2000 x 1000 x 2000mm
DRAWN BY	J. Ellison	DATE	15/12/2021						EXTERNAL DIMENSIONS	2202 x 1202 x 2093mm
CUSTOMER	CUSTOMER		ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED	A4	ALL DIMENSIONS IN MM - DO NOT SCALE				NOM. CAPACITY	4000 Litres
									DRY WEIGHT	300 KG
									INSULATION THICKNESS	25mm
									WRAS CERT. NUMBER	131006
									MATERIAL	GRP
									SCALE:	1:40
									SHEET	1 OF 1