



A

TITLE  
PW250.INS-2.AG

NOTE:

All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DRAWN BY  
C.MORRIS DATE  
05/12/2017CUSTOMER  
CUSTOMERALL DIMENSIONS +/- 5mm  
UNLESS OTHERWISE STATED

A4

ALL DIMENSIONS IN MM - DO NOT SCALE

DATE  
04/10/2017  
VERSION  
A  
NOTES  
FIRST ISSUE

TANK SPECIFICATION :

INTERNAL DIMENSIONS	1000 x 500 x 500mm
EXTERNAL DIMENSIONS	1180 x 680 x 536mm
NOM. CAPACITY	250 Litres
DRY WEIGHT	20 KG
INSULATION THICKNESS	25mm
WRAS CERT. NUMBER	131006
MATERIAL	GRP

purewater  
storage ltd  
SCALE:1:15 SHEET 1 OF 1