



D

C

B

A

D

C

B

A

TITLE
PW305.INS-2.AG

NOTE:
All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DRAWN BY C.MORRIS **DATE** 05/12/2017

CUSTOMER

CUSTOMER
ALL DIMENSIONS +/- 5mm
UNLESS OTHERWISE STATED

A4

ALL DIMENSIONS IN MM - DO NOT SCALE

DATE 05/10/2017 **VERSION** A **NOTES** FIRST ISSUE

TANK SPECIFICATION :

INTERNAL DIMENSIONS	500 x 500 x 1220mm
EXTERNAL DIMENSIONS	690 x 690 x 1229mm
NOM. CAPACITY	305 Litres
DRY WEIGHT	20 KG
INSULATION THICKNESS	25mm
WRAS CERT. NUMBER	131006
MATERIAL	GRP

purewater
storage ltd
SCALE:1:20 SHEET 1 OF 1