



TITLE		NOTE:	DESCRIPTION:	DATE	VERSION	NOTES	TANK SPECIFICATION :	
PW125.INS-2.AG		All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.	PW125-2 piece cold water storage tank suitable for AG/AF Air gap	02/10/2017	A	FIRST ISSUE	INTERNAL DIMENSIONS	500 x 500 x 500mm
DRAWN BY	C.MORRIS	DATE	05/12/2017				EXTERNAL DIMENSIONS	690 x 690 x 509mm
CUSTOMER	CUSTOMER		ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED	A4	ALL DIMENSIONS IN MM - DO NOT SCALE		NOM. CAPACITY	125 Litres
							DRY WEIGHT	10 KG
							INSULATION THICKNESS	25mm
							WRAS CERT. NUMBER	131006
							MATERIAL	GRP
							SCALE:	1:10
							HEET 1 OF 1	