







D



C



B

A

TITLE
PW340.INS-2.AG

NOTE:

All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DRAWN BY C.MORRIS **DATE** 05/12/2017

CUSTOMER

ALL DIMENSIONS +/- 5mm
UNLESS OTHERWISE STATED

A4

ALL DIMENSIONS IN MM - DO NOT SCALE

DATE 08/09/2017 **VERSION** A **NOTES** FIRST ISSUE

TANK SPECIFICATION :

INTERNAL DIMENSIONS	915 x 610 x 610mm
EXTERNAL DIMENSIONS	1090 x 785 x 641mm
NOM. CAPACITY	340 Litres
DRY WEIGHT	22 KG
INSULATION THICKNESS	25mm
WRAS CERT. NUMBER	131006
MATERIAL	GRP

purewater
storage ltd
SCALE 1:15 SHEET 1 OF 1