



TITLE		<p>NOTE: All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.</p>
PW250.INS.AB.4		
DRAWN BY	DATE	
C.MORRIS	03/05/2023	
CUSTOMER		
CUSTOMER		

TITLE		<p>NOTE: All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.</p>
PW250.INS.AB.4		
DRAWN BY	DATE	
C.MORRIS	03/05/2023	
CUSTOMER		
CUSTOMER		

DESCRIPTION:		<p>PW250 one piece cold water storage tank c/w raised float valve housing to provide an AB Air gap</p>
PW250 one piece cold water storage tank c/w raised float valve housing to provide an AB Air gap		
ALL DIMENSIONS IN MM - DO NOT SCALE		

DATE	VERSION	NOTES
04/10/2017	A	FIRST ISSUE

TANK SPECIFICATION :	
INTERNAL DIMENSIONS	1000 x 500 x 500mm
EXTERNAL DIMENSIONS	1160 x 660 x 825mm
NOM. CAPACITY	250 Litres
DRY WEIGHT	20 KG
INSULATION THICKNESS	25mm
WRAS CERT. NUMBER	131006
MATERIAL	GRP

SCALE:1:20 SHEET 1 OF 1