



TITLE  
**PW4500.INS.AB.4**

DRAWN BY **J. Ellison** DATE **23/05/2023**

**NOTE:**  
All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DESCRIPTION:  
PW4500 one piece cold water storage tank c/w raised float valve housing to provide an AB Air gap

DATE	VERSION	NOTES
27/10/2017	A	FIRST ISSUE

TANK SPECIFICATION :	
INTERNAL DIMENSIONS	2500 x 1500 x 1200mm
EXTERNAL DIMENSIONS	2694 x 1694 x 1525mm
NOM. CAPACITY	4500 Litres
DRY WEIGHT	250 KG
INSULATION THICKNESS	25mm
WRAS CERT. NUMBER	131006
MATERIAL	GRP



CUSTOMER

ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED

A4 ALL DIMENSIONS IN MM - DO NOT SCALE

SCALE: 1:30

SHEET 1 OF 1