



TITLE  
**PW3185.INS-2.AB.4**

DRAWN BY  
**C.MORRIS**

DATE  
**05/12/2017**

CUSTOMER  
**CUSTOMER**

**NOTE:**  
 All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

ALL DIMENSIONS +/- 5mm  
 UNLESS OTHERWISE STATED

DESCRIPTION:  
 PW3185-2 piece cold water storage tank  
 c/w raised float valve housing to provide an  
 AB Air gap

A4

ALL DIMENSIONS IN MM - DO NOT SCALE

DATE	VERSION	NOTES
02/10/2017	A	FIRST ISSUE

**TANK SPECIFICATION :**

INTERNAL DIMENSIONS	2440 x 1220 x 1070mm
EXTERNAL DIMENSIONS	2610 x 1410 x 1380mm
NOM. CAPACITY	3185 Litres
DRY WEIGHT	175 KG
INSULATION THICKNESS	25mm
WRAS CERT. NUMBER	131006
MATERIAL	GRP

SCALE:1:30

SHEET 1 OF 1