



A

TITLE		NOTE:		DESCRIPTION:			TANK SPECIFICATION :		
PW1000-UN		All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.		PW1000-UN One piece cold water storage tank suitable for AG/AF Air gap			DATE	VERSION	NOTES
DRAWN BY	J. Ellison	DATE	07/01/2022				07/01/2022	A	FIRST ISSUE
CUSTOMER	CUSTOMER	ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED		A4	ALL DIMENSIONS IN MM	DO NOT SCALE	INTERNAL DIMENSIONS	1000 x 1000 x 1000mm	
6	5	4	3	2	1		EXTERNAL DIMENSIONS	1180 x 1180 x 1093mm	
							NOM. CAPACITY	1000 Litres	
							DRY WEIGHT	54 KG	
							INSULATION THICKNESS	NONE	
							WRAS CERT. NUMBER	131006	
							MATERIAL	GRP	
							SCALE:	1:25	SHEET 1 OF 1

purewater
storage ltd